



Connecticut Water

TOWN OF TOLLAND
FIRE HYDRANT LOCATIONS
WITH APPROX. FIRE FLOWS

MAY 2025

SCALE
0 375 750 1,500 2,250 3,000
Feet

LEGEND

● CLASS AA 1,500 GPM OR GREATER	● CLASS A 1,000 - 1,499 GPM	● CLASS B 500 - 999 GPM	● CLASS C LESS THAN 500 GPM	⊗ PRIVATE HYDRANT NOT OWNED OR MAINTAINED BY CWC <small>*ALL PRIVATE HYDRANTS MAY NOT BE LOCATED</small>
				Water Mains Diameter
				— 4 and Under
				— 6"
				— 8"
				— 10"
				— 12"
				— 14-16"

NOTE:
FLOWS ARE BASED ON COMPUTER MODEL SIMULATION OF DISTRIBUTION SYSTEM FLOWING ONE HYDRANT USING AVERAGE SUMMER DAY DEMANDS. THESE RESULTS ARE FOR ESTIMATION PURPOSES ONLY AND MAY NOT REFLECT ACTUAL WATER AVAILABILITY.

